



# Certificate of Compliance

**Certificate:** 2235006

**Master Contract:** 229226

**Project:** 70003329

**Date Issued:** February 11, 2014

**Issued to:** Yaskawa America, Inc  
2121 Norman Dr S  
Waukegan, IL 60085  
USA  
Attention: Dmitriy Leytman

*The products listed below are eligible to bear the CSA Mark shown*



*Anne Drouin*

**Issued by:** Anne Drouin

CSA B44.1-11 /  
ASME A17.5-2011

## **PRODUCTS**

**CLASS 3211 06** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers -  
Miscellaneous

**CLASS 2411 02** - ELEVATOR EQUIPMENT-Enclosed Elevator - and Escalator Electrical  
Equipment

Variable Speed Drives for AC Motors, Series CIMR,..., followed by A, E, H, L, P or T, followed by A through Z, followed by 2, 4 or 5 followed by A through Z (except for letter T), followed by XXXX, where XXXX is 0002 through 1200, followed by A, B, C, D, F, or U, followed by XX, where XX is AA through ZZ; enclosed;

Ratings:

Input: 200 to 240Vac, 3.9A to 471A, 50/60Hz; Output: 0-240V, 3.5A to 415A

Input: 380 to 480Vac, 2.1A to 1200A, 50/60Hz; Output: 0-480V, 2.1A to 1200A

Input: 500 to 600Vac, 3.6A to 263A, 50/60Hz; Output: 0-600V, 2.7A to 242A

Notes:

Note: Motor overload Protection. The control software provides solid state overload motor protection, Class 20.

## **APPLICABLE REQUIREMENTS**



**Certificate:** 2235006

**Master Contract:** 229226

**Project:** 70003329

**Date Issued:** February 11, 2014

---

- CAN/CSA-C22.2 No. 0-10 - General Requirements - Canadian Electrical Code, Part II
- CSA-C22.2 No 14-13 - Industrial Control Equipment
- CSA B44.1-11 / ASME A17.5-2011 - Elevator and Escalator Electrical Equipment
- \*ANSI/UL508C (3rd Edition) - Power Conversion Equipment
- \*ANSI/UL 746C (6th Edition) - Standard for Polymeric Materials – Use in Electrical Equipment
- \* Used as a guide