



# Certificate of Compliance

**Certificate:** 2652285

**Master Contract:** 229226

**Project:** 70037464

**Date Issued:** 2015-07-20

**Issued to:** Yaskawa America, Inc  
2121 Norman Dr S  
Waukegan, Illinois 60085  
USA

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Patrick Quinty  
Patrick Quinty

CSA B44.1 / ASME A17.5

## **PRODUCTS**

CLASS - C321106 - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Miscellaneous

CLASS - C241101 - ELEVATOR EQUIPMENT-Open and Enclosed-Elevator Electrical Equipment

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Power Conversion Equipment, Regenerative Converter, consisting of:

Model CIMR, followed by D, followed by A through Z, followed by 2 or 4, followed by A through Z, followed by XXXX, where XXXX is 0005 through 0630, followed by XXX, where XXX can be any alphanumerical character;

## **Electrical Ratings:**

Input: 200 to 240Vac, 15A to 400A, 50/60Hz; Output: 330Vdc, 15A to 394A, 5 to 130kW.

Input: 380 to 480Vac, 8A to 1040A, 50/60Hz; Output: 660Vdc, 8A to 955A, 5 to 630kW.

## **APPLICABLE REQUIREMENTS**

- |                                |   |   |
|--------------------------------|---|---|
| CSA-C22.2 No. 14-13            | - | Industrial Control Equipment                |
| CSA-C22.2 No. 274-13           | - | Adjustable speed drives                     |
| CSA B44.1-14 / ASME A17.5-2014 | - | Elevator and Escalator Electrical Equipment |



## *Supplement to Certificate of Compliance*

**Certificate:** 2652285

**Master Contract:** 229226

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

| <b>Project</b> | <b>Date</b> | <b>Description</b>  |
|----------------|-------------|---|
| 70037464       | 2015-07-20  | Addition of alternate accepted recognize cooling fans.  |
| 70010392       | 2014-09-25  | Addition of alternative DC bus insulator/support material and design and addition of CSA C22.2 no.274-13 as applicable requirements.  |
| 2686133        | 2013-12-13  | Report update for adding alternate Accepted Fuses.  |
| 2652285        | 2013-09-17  | CSA Certification of Power Conversion Equipment, Regenerative Converter, D1000 Series, to the requirements of Standards CSA-C22.2 No.14-13 and CSA-B44.1-11/ ASME A17.5-2011. |