



CERTIFICATE OF COMPLIANCE
SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS



Certification No.

VMA-53982-01C (Revision 0)

Expiration Date: 3/31/2024

Certification Parameters:

The nonstructural products (mechanical and/or electrical components) listed on this certificate are CERTIFIED¹ FOR SEISMIC APPLICATIONS in accordance with the following building code² releases.

IBC 2021, 2018, 2015, 2012

The following model designations, options, and accessories are included in this certification. Reference report number VMA-53982-01 as issued by The VMC Group for a complete list of certified models, included accessories/options, and certified installation methods.

Yaskawa America; Variable Frequency Drives and Panels
HV6/FP6/WM6, GA7/GA8, and GA5; Max. 720 Amp Output Current

The above referenced equipment is APPROVED for seismic application when properly installed³, used as intended, and contains a Seismic Certification Label referencing this Certificate of Compliance⁴. As limited by the tabulated values, below grade, grade, and roof-level installations, installations in essential facilities, for life safety applications, and/or of equipment containing hazardous contents are permitted and included in this certification with an Equipment Importance Factor assigned as $I_p=1.5$. The equipment is qualified by successful seismic shake table testing at the nationally recognized Dynamic Certification Laboratories under the witness of the ISO Accredited Product Certification Agency, the VMC Group.

Certified Seismic Design Levels			
Certified IBC	Importance $I_p \leq 1.5$ Soil Classes A-E Risk Categories I-IV Design Categories A-F	$z/h \leq 1.0$	$z/h = 0.0$
		$S_{DS} \leq 2.000 \text{ g}$	$S_{DS} \leq 2.500 \text{ g}$

Certified Seismic Installation Methods	
Directly To Structural Wall	Directly To Non-Structural Wall/Enclosure

HEADQUARTERS
113 Main Street
Bloomington, NJ 07403
Phone: 973.838.1780
Toll Free: 800.569.8423
Fax: 973.492.8430

CALIFORNIA
180 Promenade Circle
Suite 300
Sacramento, CA 95834
Phone: 916.634.7771

TEXAS
11930 Brittmoore Park Drive
Houston, TX 77041
Phone: 713.466.0003
Fax: 713.466.1355

thevmcgroup.com





CERTIFICATE OF COMPLIANCE
SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Certified Product Table:

Product Type	Max Output Current (A)	Max Nominal HP	Input Voltages	Enclosure Type	Panel Cabinet Sizes	Drive Frame Sizes	Max. Length [in.]	Max. Width [in.]	Max. Height [in.]	Max. Weight [lbs.]
Bypass Panels	77	60	208, 240, 480	Type 1	W1 - W4	1 - 4	16.6	12.5	52.1	119
Configured Panels	114	75					15.1	11.0	45.8	108
HV6/FP6/WM6 Drives	720	600	240, 480	Open	N/A	1, 2, 3, 4, 6, 9, 10, 11	18.9	20.1	44.7	493
				Type 1		1, 2, 3, 4, 6, 9, 10, 10B, 11				
	169	125		Type 12		1, 2, 3, 4, 6	16.1	14.5	31.7	178
				Type 12 w/ Switch			17.8		48.7	220
GA7/GA8 Drives	720	600	240, 480, 600	Open		9, 10, 11	18.9	20.1	44.7	455
				Type 1		9, 10A, 10B, 11		20.2	70.6	540
GA5 Drives	82	40	Single Phase 240, 3-Phase 240, 480	Open		1, 2, 3, 4, 5, 6, 7, 8	9.9	8.7	13.8	19
				Type 1		7.4	16.1		21	

Group	Type	S _{DS} (z/h=1)	S _{DS} (z/h=0)	A _{Flex-H}	A _{Rig-H}	A _{Flex-V}	A _{Rig-V}	F _p /W _p
Seismic	AC156	2.00	2.50	3.20	2.40	1.68	0.68	4.50

This certification includes the listed Drives and Panels, with included factory supplied options. This certification only covers accessories and options directly mounted to the drives and panels. The drives, panels, and applicable options shall be installed per the manufacturer supplied seismic installation instructions. For a list of certified configurations and options please contact the manufacturer directly. This certification excludes all non-factory supplied accessories and options, including but not limited to isolation/restraint devices, other electrical/mechanical components and all connections for electrical, fuel, heating or cooling fluid, or other pipe/conduit connections and configurations not detailed in the above charts. Flexibility in the connections must be maintained as to not transmit load into the equipment. Design specials are outside the scope of this certification.



VMA-53982-01C (Revision 0)
Issue Date: Wednesday, March 10, 2021
Revision Date: Tuesday, March 16, 2021
Expiration Date: Sunday, March 31, 2024



CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Notes & Comments:

1. All equipment listed herein successfully passed the seismic acceptance criteria for shake testing non-structural components and systems as set forth in the ICC AC-156. The Test Response Spectrum (TRS) enveloped the Required Response Spectrum (RRS) for all units tested. The tested units were representative sample(s) of a contingent of models and all remained captive and structurally sound after the seismic shake simulation. The units also remained functionally operational after the simulation testing as functional testing was completed by the equipment manufacturer before and after the seismic simulations. Although a seismic qualified unit inherently contains some wind resisting capacity, that capacity is undetermined and is excluded from this certification. Snow/Ice loads have been neglected and thus limit the unit to be installed both indoors (covered by an independent protective structure) and out of doors (exposed to accumulating snow/ice) for ground snow loads no greater than 30 psf for all applications.
2. The following building codes are addressed under this certification:
 - IBC 2021 referencing ASCE7-16 and ICC-ES AC-156
 - IBC 2018 referencing ASCE7-16 and ICC-ES AC-156
 - IBC 2015 referencing ASCE7-10 and ICC-ES AC-156
 - IBC 2012 referencing ASCE7-10 and ICC-ES AC-156
3. Refer to the manufacturer supplied installation drawings for anchor requirements and mounting considerations for seismic applications. Required anchor locations, size, style, and load capacities (tension and shear) may be specified on the installation drawings or specified by a 3rd party. Mounting requirement details such as anchor brand, type, embedment depth, edge spacing, anchor-to-anchor spacing, concrete strength, special inspection, wall design, and attachment to non-building structures must be outlined and approved by the Engineer of Record for the project or building. Structural walls, structural floors, and housekeeping pads must also be seismically designed and approved by the project or building Structural Engineer of Record to withstand the seismic anchor loads as defined on the installation drawings. The installing contractor is responsible for ensuring the proper installation of all anchors and mounting hardware.
4. For this certificate and certification to remain valid, this certificate must correspond to the "Seismic Certification Label" found affixed to the unit by the factory. The label ensures the manufacturer built the unit in conformance to the IBC seismic design criteria set forth by the Certified Seismic Qualification Agency, the VMC Group, and meets the seismic design levels claimed by this certificate.
5. Mechanical, Electrical, and Plumbing connections to the equipment must be flexibly attached as to not transfer load through the connection. The structural integrity of any conduit, cable trays, piping, ductwork and/or flexible connections is the responsibility of others. This certification does not guarantee the equipment will remain compliant to NEMA, IP, UL, or CSA standards after a seismic event.
6. This certificate applies to units manufactured at:
 - 1067 Johnson Dr, Buffalo Grove, IL 60089
 - 150 W Oakwood Rd, Oak Creek, WI 53154
7. This certification follows the VMC Group's ISO-17065 Scheme.

John P. Giuliano, PE
President, VMC Group



VMA-53982-01C (Revision 0)
Issue Date: Wednesday, March 10, 2021
Revision Date: Tuesday, March 16, 2021
Expiration Date: Sunday, March 31, 2024

